

안전인증서

(주) 와이즈산전

경기도 용인시 기흥구 덕영대로 2022

위 사업장에서 제조하는 아래의 품목이 「산업안전보건법」 제34조 및 같은 법 시행규칙 제58조의4제4항에 따른 안전인증 심사 결과 안전·보건기준에 적합하므로 안전인증표시의 사용을 인증합니다.

품 목

Thermocouple, Resistance temperature Detector

형식·모델(용량·등급) / 인증번호

R Series

(Ex d IIC T6) / 14-KB2BO-0653

인 증 기 준

고용노동부고시 제2013-54호

인 증 조 건

1. 제조공장

본 인증서는 아래의 제조공장에서 생산하는 제품에 한함

· 제조공장명 : (주) 와이즈산전

· 소재지 : 경기도 용인시 기흥구 덕영대로 2022

2. 제품개요

· 정격 : 4 ~ 20 mA, DC 24 V

3. 인증범위 : 본 인증서는 위의 형식번호에 한하여 유효함

4. 안전한 사용을 위한 조건

· 사용주위온도 : -40℃ ~ +65℃

5. 인증(변경)사항 : 없음

6. 그 밖의 사항

· 사용설명서 참조

· 안전인증품의 품질관리, 확인심사 수검, 변경사항 신고 등 인증 받은 자의 의무 준수

2014년 10 월 28 일

한국산업기술시험원장





No. 2014-026992-03

안전인증서

Certificate of Safety

WISE CONTROL INC.

2022, DeogYeong-daero, Giheung-gu, Yongin-si, Gyeonggi-do, Korea

The following product manufactured by the above company has been authorized for the use of safety certification mark as the product has satisfied the safety and health requirements under Article 34 of OCCUPATIONAL SAFETY AND HEALTH ACT and paragraph 4 of Article 58-4 of ENFORCEMENT ORDINANCE OF the same ACT.

Electrical Equipment

Thermocouple, Resistance temperature Detector

Model (Marking) / Certificate No.

R Series (Ex d IIC T6) / 14-KB2BO-0653

Applied standards

Announcement No. 2013-54 of Ministry of Employment and Labor

Conditions of Certification

- 1. Manufacturing location(s)** : This certificate is only valid for the specified products produced at '2022, DeogYeong-daero, Giheung-gu, Yongin-si, Gyeonggi-do, Korea'.
- 2. Description of equipment**
 - Rating : 4 ~ 20 mA, DC 24 V
 - Ambient Temperature : -40 °C ≤ Ta ≤ +65 °C
- 3. Scope of certification** : This certificate is only valid for the models as above.
- 4. Special conditions for safe use** : None
- 5. Details of certificate changes** : None
- 6. Details of the others** : Manufacturer shall take the responsibility including maintaining quality requirements for the certified products, receiving factory surveillance and informing any changes to the certified products.

Date of Issue : 2014-10-28

한국산업기술시험원장
KOREA TESTING LABORATORY

