

No. 2015 - 0514



## Safety Certificate

- Manufacturer **KOREA FLOWMETER IND.CO.,LTD**
- Address **#40, Wonchang-ro 64 beon-gil, Seo-gu, Incheon, South Korea.**

The following product fabricated by the above manufacturer has been certified for the use of the Safety Certification Mark as the product was assessed and tested in accordance with the article 34 of the Occupational Safety & Health Act and the article 58 (4) 4 of the Enforcement Rule thereof.

- Product **FLOW TRANSMITTER**
- Type(Model) **KTVP-750**
- Rating **Max. DC 24V or Max. AC 220V**
- Type of Protection **Ex d IIC T5**
- Certification No. **15-GA2BO-0514**
- Safety Certification Standards **Notification of Protective device Mandatory Safety Certification  
(Notice of Ministry of Employment and of Labor No. 2013-54)**
- Certification condition **1. Tamb = - 10℃ ~ + 55℃  
2. Routine test : Each enclosure shall be subjected to overpressure  
test of 23.7 bar before product released**
- Date of issue **July 15th, 2015**

*Approved for issue on behalf of the president :* **Gi-Hoi, Kim**  
*position :* **General Manager**

*Signature*

Handwritten signature in black ink, appearing to read '김기호' (Kim Gi-ho).



**KOREA GAS SAFETY  
CORPORATION**