





시험 성적서

발행번호 : SGS-R18-2573-KR00
접수번호 : TON-R18-3505
의뢰기관 : (주)와이즈산전
회사주소 : 경기도 용인시 기흥구 덕영대로 2022 (17097)
제품명 : Cool-down and leak detector
모델명 : R190(RL Series)
시험일자 : 2018년 12월 04일 ~ 2018년 12월 16일
시험규격/방법 : IEC 60529: 2013
Degrees of protection provided by enclosures (IP66)
시험결과 : Page 9 참조.
용도 : 품질관리용

이 성적서 위의 내용은 시험의뢰인에 의해 제공된 시료에 한하며, 용도 이외의 사용을 금합니다.

확인	작성자	기술책임자
	성명 : 정상진 	성명 : 구형근 

※ 이 성적서는 서면 승인 없이 일부만 복사하여 사용할 수 없음.

2018. 12. 20.

한국에스지이에스(주) 동탄시험소장



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.





목 차

1. 시험 개요	3
2. 시료	3
2.1 내용	3
2.2 시료 사진	3
3. 시험 절차	4
3.1 동작 시험 절차	4
3.2 비동작 시험 절차	4
4. 시험 조건 및 시험 결과	4
4.1 IPX6	5
4.2 IP6X	7
※ 부록1. 외관 검사 데이터	9



1. 시험 개요

본 시험은 의뢰자의 요구에 따라서 의뢰자가 제시한 규격과 시험시료로 실시 하였음.

2. 시료

2.1 내용

- 1) 의뢰자 : (주)와이즈산전
- 2) 제조자 : (주)와이즈산전
- 3) 제품명 : Cool-down and leak detector
- 4) 모델명 : R190(RL Series)
- 5) 제조번호 : -
- 6) 시료수 : 1 EA

2.2 시료 사진







3. 시험 절차

시험 절차는 다음 두 가지 절차 중 택일 진행.

3.1 동작 시험 절차



3.2 비동작 시험 절차



4. 시험 조건 및 시험 결과



4.1 IPX6

의뢰자	(주)와이즈산전	담당부서	신뢰성 시험팀
제품명	Cool-down and leak detector	시험요원	정 상 진 (☎ 031-240-6651)
모델명	R190(RL Series)	시험일자	2018. 12. 04.
제조번호	-		
시험규격/ 방법	IEC 60529: 2013 Degrees of protection provided by enclosures	Page	2

(1) 시험 조건

- 1) IP 등급 : IPX6
- 2) 방 수 율 : 100 L/min \pm 5 %
- 3) 분무거리 : 노즐에서 시료 표면까지 (2.5 ~ 3)m
- 4) 시험시간 : 3 min (각 면당 30 s)
- 5) 시험포인트 : 총 6 포인트(전, 후, 좌, 우, 위, 아랫면)
- 6) 제품상태 : ① 비포장 상태 ② 비동작 상태
- 7) 점검시간 : 시험 후 확인
- 8) 시 료 수 : 1 EA

(2) 시험 장비

기 기 명	제조회사 및 형식	기기 번호	차기 교정 예정 일자	교정 기관
터빈유량계	Blancett 110-875	082905362	2019.03.26.	DDHT
STOP WATCH	KS-201	0704771	2020.05.28.	SICT
줄자	-	816778	2020.08.21.	SICT

(3) 시험 결과

점검 항목	시험 결과
- 시료 내부 물 침투 확인	시료 내부 물 침투 없음. (Page 9 참조.)

(4) 시험사진





4.2 IP6X

의뢰자	(주)와이즈산전	담당부서	신뢰성 시험팀
제품명	Cool-down and leak detector	시험요원	정 상 진 (☎ 031-240-6651)
모델명	R190(RL Series)	시험일자	2018. 12. 15. ~ 2018. 12. 16.
제조번호	-		
시험규격/ 방법	IEC 60529: 2013 Degrees of protection provided by enclosures	Page	2

(1) 시험 조건

- 1) IP 등급 : IP6X
- 2) 시험시간 : 8 h
- 3) 감 압 : 최대 감압이 2 kpa (20 mbar)
- 4) 시료상태 : ① 비포장 상태 ② 비동작 상태
- 5) 점검시간 : 시험 후 확인
- 6) 시험장소 : 씨티케이 (경기도 용인시 처인구 예직로 113)
- 7) 시 료 수 : 1 EA

(2) 시험 장비


기 기 명	제조회사 및 형식	기기 번호	차기 교정 예정 일자	교정 기관
Dust 챔버	KP-SC3000	KP1802012	2019.04.26	CGEL

(3) 시험 결과

점검 항목	시험 결과
- 시료 내부 분진 침투 확인.	시료 내부 분진 침투 없음. (Page 9 참조.)



(4) 시험사진





※ 부록1. 외관 검사 데이터

1. IPX6 : 시료 내부 물 침투 없음.



2. IP6X : 시료 내부 분진 침투 없음.



끝.